

#### J & E Hall Refrigeration Sdn. Bhd. (34543-W)

Lot 10, Jalan Perusahaan 8, Kawasan Perusahaan Pekan Banting, 42700 Banting, Selangor Darul Ehsan, Malaysia. Tel: +603-31872911 Fax: +603-31878597

# **Declaration of Conformity**

We declare under our sole responsibility that the following products:

## Refrigeration Scroll Condensing Unit (Series 4)

## **Model Designations:**

JEHS\*-0800-M-3, JEHS\*-1000-M-3, JEHS\*-0750-L-3, JEHS\*-1000-L-3

Which are containing refrigerating fluids classified in Group 2 and whose product PS\*V in bar×liter is such that 200 < PS\*V ≤ 1000 bar.L, are classified in category II according to article 3 of PRESSURE EQUIPMENT DIRECTIVE 97/23/EC.

Category: II

**Evaluation module: A1** 

Notified body: Hartford Steam Boiler UK Limited (2561), Birmingham, England

### **Technical standards and specification:**

are in conformity with the ELECTROMAGNETIC COMPATIBILITY 2004/108/EC and Machinery Directive 2006/42/EC.

EMC EN 61000-6-1 (2001) & EN 61000-6-3 (2001)

MD EN 60335-1 & EN 60335-2-89

The products are provided with a CE 2561 marking of conformity.

J & E HALL REFRIGERATION SDN. BHD

Teh Yeow Chong
General Manager
Issued Date: 25 November 2014

Note: \* denotes as nomenclature for different model or version of condensing unit (eg. JEHSCU & JEHS).